

From: Burton, Bridgette [mailto:bridgette.burton@bves.com]
Sent: Wednesday, April 20, 2016 7:54 AM
To: angela@scjpc.net
Cc: Cardella, Eric <Eric.Cardella@bves.com>
Subject: RE: Submit Priority Pole Definitions and Time Frames

Good morning Angela,

We follow General Order 95 Rule 18, which defines priority poles and their respective time frames.

(i) Level
1:

- Immediate safety and/or reliability risk with high probability for significant impact.
- Take action immediately, either by fully repairing the condition, or by temporarily repairing and reclassifying the condition to a lower priority.

(ii) Level 2:

- Variable(non-immediate high to low) safety and/or reliability risk.
- Take action to correct within specified time period (fully repair, or by temporarily repairing and reclassifying the condition to a lower priority).

Time period for correction to be determined at the time of identification by a qualified company representative but not to exceed: (1) 12 months for nonconformances that compromise worker safety, (2) 12 months for nonconformances that create a fire risk and are located in an Extreme or Very High Fire Threat Zone in Southern California, and (3) 59 months for all other Level 2 nonconformances.

(iii) Level 3:

- Acceptable safety and/or reliability risk.
- Take action (re-inspect, re-evaluate, or repair) as appropriate.

- b) Correction times may be extended under reasonable circumstances, such as:
- Third party refusal
 - Customer issue
 - No access
 - Permits required
 - System emergencies (e.g. fires, severe weather conditions)

Thank-you,

Bridgette Burton, RWA

Senior Engineering Estimator • Bear Valley Electric Service

A Division of Golden State Water Company

42020 Garstin Dr • PO Box 1547 • Big Bear Lake, CA 92315

☎ 909-866-4678 ext 142 | 📠 909-866-5056 fax

✉ Bridgette.Burton@bves.com