

CONFIDENTIALITY NOTICE

THIS VIDEO IS CONFIDENTIAL AND WAS CREATED FOR SCJPC MEMBERS AND THEIR CONTRACTORS. PLEASE DO NOT SHARE THIS VIDEO WITH NON MEMBERS.

4.4 Purchase of Interest at Same Grade

When purchasing same grade as another member/owner cost of that foot will be shared equally.

When attaching to an existing arm, to share the same grade, the initiating party must show the appropriate Item of "Authorized Cost". When placing a new arm, to share the same grade, the initiating party must show the appropriate item of Authorized Cost and bear the cost of transferring facilities. (See Section 14.1 and examples in Section 21, Refer to Authorized Costs Items 160 or 164). (Revised January 2009)

Go to the SCJPC Website: scjpc.net

Click on: MEMBERS

Click on: FORMS AND ROUTINE HANDBOOK

The screenshot shows the SCJPC.NET website. The top navigation bar includes links for HOME, OFFICERS, CALENDAR, GENERAL INFO, SEARCH, MEMBERS, JPA ALERT, and CONTACT. The MEMBERS dropdown menu is open, listing various options such as JPA CONTACTS, POLE INSPECTION CONTACTS AND RESOURCES, FIELD ASSISTANCE/JOINT MEET, BASIC JPA TRAINING, FORMS AND ROUTINE HANDBOOK (highlighted), POLE PRICES AND AUTHORIZED COSTS, AGENDA, MEETING MINUTES, MEETING ATTENDANCE POLICY, BOARD ATTENDANCE, AGREEMENT AND BY-LAWS, DISPUTE RESOLUTION, TECHNICAL RESOURCES, PRIORITY POLES DEFINITIONS, CABLE AND POLE TAGS, STANDARDS FOR CONTRACTOR QUALIFICATIONS, and APPROVED CONTRACTORS LIST. The background shows a banner for Southern California and a table of current members.

Current members of Southern California Joint Pole Committee are:

Southern California Edison (E)	
Frontier Communications (FTR)	
City of Anaheim (D)	
City of Glendale (A)	
City of Burbank (B)	
MCI Metro/ATS (ATS)	City of Azusa (MA)
City of Colton (F)	City of Lompoc (LLW)
AT&T Mobility (LAC)	MCI Telecommunications (MCI)
M-Power/Telepacific Communications (ICG)	Sprint Nextel Corporation (SPR)
T-Mobile USA Inc. (DBM)	VN Communications (NVT)

Scroll down the page and click on: SCJPC Routine Handbook 2023 Edition.pdf

The screenshot shows the SCJPC.NET website displaying a list of forms and routine handbooks. The list includes various forms such as FORM 7, FORM 9, FORM 11, FORM 16, FORM 48, FORM 49, and FORM 50. Below the forms, there is a section titled 'ROUTINE HANDBOOK' with a list of handbooks from 2018 to 2023. The 'SCJPC Routine Handbook 2023 Edition.pdf' is highlighted in yellow.

Document Name	File Size	Update Date
FORM 7	18.7 KB	
FORM 9 - Joint Pole Riser Notification	31.5 KB	updated 8/12/2008
FORM 11 - Notification of G.O. 95 Non-Conformance	25.4 KB	updated 1/19/2016
FORM 16 - Reallocation of Space	28.0 KB	
FORM 16 Instructions	15.0 KB	
Form 48 - Notice of Work Completed	116.0 KB	Approved 4/18/2018
FORM 49 - Tracer	20.5 KB	updated 1/06/2010
Form 50 - GPS Coordinates.xlsx	14.6 KB	Approved 8/17/2022
ROUTINE HANDBOOK		
SCJPC Routine Handbook 2023 Edition.pdf	5.5 MB	1/20/2023
SCJPC Routine Handbook 2022 Edition 03152022.pdf	3.8 MB	Updated 03/15/2022*
SCJPC Routine Handbook 2021 Edition_08122021.pdf	4.5 MB	Updated 08/12/2021*
SCJPC Routine Handbook 2020 Edition 11112020.pdf	2.8 MB	Updated 11/11/2020*
SCJPC Routine Handbook 2019 Edition	3.1 MB	Updated 07/15/2019*
SCJPC Routine Handbook 2018 Edition	3.3 MB	Updated 06/08/2018*



SOUTHERN CALIFORNIA JOINT POLE COMMITTEE

**ROUTINE HANDBOOK
2023 EDITION**

Confidential

GRADE AND SPACE ALLOCATION EXPLANATION

16.1 A-Grade

Grade is measured from the ground line to the attachment in question. The average grade of the top position on a pole and other pertinent attachment information shall be assumed to be as follows (the top conductor is not necessarily at the same height):

Pole Ht	Top Grd	Ft in Grnd	Supp Struc	Safe Clear	Common Area	Use Ft
25'	20'	5'	14'	4'	23'	2'
30'	25'	5'	16'	4'	25'	5'
35'	30'	5'	18'*	6'	29'	6'
40'	34'	6'	18'	6'	30'	10'
45'	39'	6'	18'	6'	30'	15'
50'	43'	7'	18'	6'	31'	19'
55'	48'	7'	18'	6'	31'	24'
60'	52'	8'	18'	6'	32'	28'
65'	57'	8'	18'	6'	32'	33'
70'	61'	9'	18'	6'	33'	37'
75'	66'	9'	18'	6'	33'	42'
80'	70'	10'	18'	6'	34'	46'
85'	75'	10'	18'	6'	34'	51'
90'	79'	11'	18'	6'	35'	55'
95'	84'	11'	18'	6'	35'	60'
100'	89'	11'	18'	6'	35'	65'

*Per Clearance Requirements (Revised January 2012)

