

General Order 95-Rule 18A Timeframes for Corrective Action

Level 1 - Immediate Safety and/or Reliability Risk with High Probability for Significant Impact

1	Electric Trouble Board Notified	Within 24 Hours
----------	--	------------------------

Level 2 - Variable (Non-Immediate High to Low) Safety and/or Reliability Risk

2A	Non-Conformances that Compromise Worker Safety	Within 12 Months
-----------	---	-------------------------

2B	Non-Conformances/Fire Risk in Fire Threat Zone	Within 12 Months
-----------	---	-------------------------

2C	For All Other Level 2 Non-Conformances	Within 59 Months
-----------	---	-------------------------

Level 3 - Acceptable Safety and/or Reliability Risk

3	Minor Non-Conformance or Opportunity Maintenance	Correct During Routine Work
----------	---	------------------------------------

Level 4 - Data Communication

4A	Information and Record Data	As Appropriate
-----------	------------------------------------	-----------------------

4B	Forwarded to Eng./ODD/Contract Ops.	As Appropriate
-----------	--	-----------------------